

Review of WF Assessment Report No. 187254

1. Introduction

WF Assessment Report No. 187254 presents an appraisal of the fire resistance performance of a range of glazed and un-glazed fibreglass faced and phenolic aldehyde foam cored doorsets supplied by Phoenix Door Panels limited.

The report considers that the fire doors should be capable of providing up to 30 minutes integrity if tested utilising the general principles of BS 476: Part 22:1987.

2. Confirmation of Specification

It has been confirmed by Phoenix Door Panels Limited that there have been no changes to the specification considered in the original appraisal referenced WF Assessment Report No. 187254.

3. Conclusions

The data used for the original appraisal has been re-examined and found to be satisfactory.

The procedures adopted for the original test have been re-examined and are similar to those currently in use.

Therefore, with respect to the assessment of performance given in WF Assessment Report No. 187254, the contents should remain valid for a further period of five years, i.e. until 9th March 2020.

4. Validity

This review is based on information used to formulate the original assessment. No other information or data has been provided by Phoenix Door Panels Limited which could affect this review.

The original appraisal report was performed in accordance with the principles of the UK Fire Test Study Group Resolution 82: 2001. This review has therefore also been conducted using the same principles.

This report remains valid until 9th March 2020 after which it is recommended that the assessment should be reviewed.

Performed by:



A Stevenson
Senior Certification Engineer
Exova Warringtonfire

Reviewed by:



D Hankinson
Principal Certification Engineer
Exova Warringtonfire

This copy has been produced from a .pdf format electronic file that has been provided by Exova Warringtonfire to the sponsor of the report and must only be reproduced in full. Extracts or abridgements of reports must not be published without permission of Exova Warringtonfire. The pdf copy supplied is the sole authentic version of this document. All pdf versions of this report bear authentic signatures of the responsible Exova Warringtonfire staff.